

**PG&E Transmission Incidents 2002 - 2009**

Date	City	County	State	Class	Fatalities	Injuries	Property Damage	High Consequence Area	Ignition	Exposion	Evacuation	Maximum Allowable Operating Pressure of Pipeline	Part that failed	Cause
6/11/02	FRESNO	FRESNO	CA	1	0	1	\$60,000	No	No	No	No	650	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
4/1/03	TEMPLETON	SAN LUIS OBISPO	CA	1	0	0	\$77,000	No	No	No	No	650	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
8/22/03	MADERA	MADERA	CA	1	1	1	\$490,000	No	Yes	No	Yes	400	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
9/6/04	DOS PALOS	MADERA	CA	1	0	0	\$75,000	No	Yes	No	No	625	JOINT	FIRE/EXPLOSION AS PRIMARY CAUSE
6/28/05	SHAFTER	KERN	CA	1	0	0	\$204,000	No	No	No	No	757	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
9/28/05	FOLSOM	SACRAMENTO	CA	3	0	0	\$120,000	No	No	No	No	500	JOINT	MALFUNCTION OF CONTROL/RELIEF EQUIPMENT
11/19/05	SALINAS	MONTEREY	CA	1	0	0	\$60,354	No	No	No	No	350	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
8/19/06	MAD RIVER	TRINITY	CA	1	0	0	\$358,000	No	No	No	No	819	BODY OF PIPE	EARTH MOVEMENT
11/20/06	STOCKTON	SAN JOAQUIN	CA	1	0	1	\$350	No	No	No	No	2160	OTHER	COMPONENT
1/16/07	HEALDSBURG	SONOMA	CA	2	0	0	\$500,000	No	No	No	No	720	BODY OF PIPE	CORROSION, EXTERNAL
8/28/07	CHOWCHILLA	MERCED	CA	1	0	0	\$45,000	No	No	No	Yes	625	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
9/13/07	AVENAL	KINGS	CA	1	0	0	\$122,500	No	No	No	No	840	BODY OF PIPE	INCORRECT OPERATION
3/31/08	GLENN	GLENN	CA	1	0	0	\$43,800	No	No	No	Yes	275	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
7/21/08	EUREKA	HUMBOLDT	CA	3	0	0	\$70,500	No	No	No	No	167	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
3/19/09	ARBUCKLE	COLUSA	CA	3	0	0	\$52,000	No	No	No	No	150		OPERATOR EXCAVATION DAMAGE
4/3/09	SALINAS	MONTEREY	CA	1	0	0	\$1,510,000	No	No	No	No	313	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
10/22/09	SALINAS	MONTEREY	CA	1	0	0	\$85,000	No	No	No	No	408	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
11/11/09	SAN FRANCISCO	SAN FRANCISCO	CA	3	0	0	\$50,000	No	No	No	No	275	BODY OF PIPE	THIRD PARTY EXCAVATION DAMAGE
12/9/09	ELK GROVE	SACRAMENTO	CA	3	0	0	\$150,000	No	No	No	No	410	BODY OF PIPE	CORROSION, EXTERNAL